

**WASHINGTON STATE
BUILDING CODE**

CHAPTER 51-55 WAC

**2021 WASHINGTON WILDLAND-URBAN
INTERFACE CODE**

First Edition



Washington State Building Code Council

First Edition Effective July 1, 2023

Copies of the State Building Codes and
complete copies of the 2021 Washington Wildland-Urban Interface Code
as published by the International Code Council
may be obtained from:

Washington Association of Building Officials
Post Office Box 7310
Olympia, Washington 98507-7310
(360) 628-8669 www.wabobookstore.org
or toll free in Washington State at (888) 664-9515

First Edition
Washington Wildland-Urban Interface Code
Chapter 51-55 WAC
Effective July 1, 2023
First Edition based on
WSR 23-02-056

Preface

Authority: The Washington Wildland-Urban Interface Code (Chapter 51-55 WAC) is adopted by the Washington State Building Code Council pursuant to Chapters 19.27 and 70.92 RCW. The Washington State Building Code was first adopted by reference by the Washington State Legislature in 1974. In 1985, the Legislature delegated the responsibility of adoption and amendment of these codes to the State Building Code Council. The first adoption of the International Residential Code was in 2004.

Code Precedence: The State Building Code Act, Chapter 19.27 RCW, establishes the following order of precedence among the documents adopted as parts of the State Building Code:

International Building Code, Standards and amendments – WAC 51-50.

International Residential Code, Standards and amendments – WAC 51-51.

International Mechanical Code, Standards and amendments – WAC 51-52.

International Fire Code, Standards and amendments – WAC 51-54A.

Washington Wildland-urban Interface Code – WAC 51-55

Uniform Plumbing Code, Standards and amendments – WAC 51-56.

Where there is a conflict between codes, an earlier named code takes precedence over a later named code. In the case of conflict between the duct insulation requirements of the International Mechanical Code and the duct insulation requirements of the Energy Code, the Energy Code, or where applicable, a local jurisdiction's energy code, shall govern.

Where, in any specific case, different sections of this Code specify different materials, methods of construction or other requirements, the most restrictive shall govern. Where there is conflict between a general requirement and a specific requirement, the specific requirement shall be applicable.

Organization and Numbering: These rules are written to allow compatible use with the International Mechanical Code. All sections which are amended, deleted, or added are referenced.

Enforcement: The State Building Code Act requires that each local jurisdiction enforce the State Building Code within its jurisdiction. Any jurisdiction can contract with another jurisdiction or an inspection agency to provide the mandated enforcement activities.

Amendments to the State Building Code:

The State Building Code Council has adopted review procedures and approval criteria for local amendments. These procedures and criteria are found in Chapter 51-04 WAC. The Council has exempted from its review any amendments to the administrative provisions of the various codes.

Forms for proposing statewide amendments to the State Building Code are available from the State Building Code Council staff.

- A. **Amendments of Statewide Application:** On a yearly basis the State Building Code Council will consider proposals to amend the State Building Code. The Council is not scheduled to enter formal rulemaking until 2021 as part of its consideration of adoption of the 2021 series of codes.

Proposals to amend the State Building Code shall be made on forms provided by the Building Code Council.

- B. **Local Amendments:** Any jurisdiction may amend the State Building Code provided the amendments do not reduce the minimum performance standards of the codes. There are two areas where local amendments are limited or prohibited:

Prohibited Amendments: Residential provisions of the State Energy Code (WAC 51-11R and WAC 51-11C); any provision of the International Building Code or International Residential Code affecting accessibility; and standards specifically adopted in Chapters 19.27 and 19.27A WAC cannot be amended by any local jurisdiction.

Residential Amendments: Amendments by local jurisdictions which affect the construction of single family and multi-family residential buildings must be reviewed and approved by the State Building Code Council before such amendments can be enforced. The State Building Code Act provides the following definition:

Multi-family residential building means common wall residential buildings that consist of four or fewer units, that do not exceed two stories in height, that are less than 5,000 square feet in area, and that have a one-hour fire-resistive occupancy separation between units.

Application forms for Council review of local amendments are available from the State Building Code Council Staff.

Washington State Building Code Council

Post Office Box 41449

Olympia, Washington 98504-1449

www.sbcc.wa.gov

(360) 407-9255

e-mail: sbcc@des.wa.gov

Printing Format: This version of the rules is published as a series of insert or replacement pages and is intended to be printed as a two-sided document. Each page provides instructions for installing them in the model code book. Amendments to the model code, are indicated by a double line in the margin next to the revised portions. Any portion of the model code that has been deleted in the amendment will be marked with a > symbol

Effective Date: These rules were adopted by the State Building Code Council on November 18, 2022. The rules are effective throughout the state on July 1, 2023. This code is based on WAC 51-55 as published in WSR 23-02-056. It is subject to review by the State Legislature during the 2024 session.

Insert Page A-3

Insert Facing Insert Page A-4

Building Permit Fees: The activities of the State Building Code Council are supported by permit fees collected by each city and county. Section 19.27.085 of the State Building Code Act requires that a fee of \$6.50 be imposed on each residential permit and \$25.00 on each commercial building permit issued by each city and county. In addition, a fee of \$2.00 per unit shall be imposed for each dwelling unit after the first unit, on each building containing more than one residential unit. For the purpose of this fee, WAC 365-110-035 defines building permits as any permit to construct, enlarge, alter, repair, move, improve, remove, convert or demolish any building or structure regulated by the Building Code. Exempt from the fee are plumbing, electrical, mechanical permits, permits issued to install a mobile/manufactured home, commercial coach or factory-built structure, or permits issued pursuant to the International Fire Code.

Each city and county shall remit moneys collected to the state treasury quarterly. No remittance is required until a minimum of \$50.00 has accumulated.

These permit fees are the amounts current in January 2020. Such fees may be changed by the State Legislature.

Opinions: RCW 19.27.031 grants the council authority to render opinions relating to the building code at the request of a local code official. For the purposes of this section, the term "code official" means the local or state official, or their designee, responsible for implementation and enforcement of the specific code provision on which the opinion is requested.

At the request of a code official, the council will issue opinions relating to the codes adopted under chapters 19.27, 19.27A, and 70.92 RCW, and council amendments to the model codes. At the request of a local code official, the council may issue opinions on the applicability of WAC 51-04-030 to a local government ordinance regulating construction. Council related opinions may be developed and approved by a standing committee of the council. Opinions approved by a standing committee may be reviewed and modified by the council.

Table of Contents

WAC 51-55-001	Authority	A
WAC 51-55-002	Purpose	A
WAC 51-55-003	International Residential Code	A
WAC 51-55-008	Implementation	A
 Chapter 1 Scope and Administration		
WAC 51-55-0100	Section R101 – Scope and General Requirements	1-1
WAC 51-55-0200	Chapter 2 Definitions	
WAC 51-55-0300	Wildland - Urban Interface Areas	
WAC 51-55-0400	Wildland - Urban Interface Area Requirements	
WAC 51-55-0500	Special Building Construction Regulations	
WAC 51-55-0600	Fire Protection Requirements	
WAC 51-55-0700	Chapter 7 - Vegetation Management Plan	
WAC 51-55-0800	Chapter 8 - Fire Hazard Severity Form	
WAC 51-55-0900	Chapter 9 - Fire Danger Rating System	
WAC 51-55-1000	Chapter 10 - Referenced Standards	

WAC 51-55-001 Authority.

These rules are adopted under the authority of chapter [19.27](#) RCW.

WAC 51-55-002 Purpose.

The purpose of these rules is to implement the provisions of chapter [19.27](#) RCW, which provides that the state building code council shall maintain the state building code in a status which is consistent with the purpose as set forth in RCW [19.27.020](#). In maintaining the codes, the council shall regularly review updated versions of the codes adopted under the act, and other pertinent information, and shall amend the codes as deemed appropriate by the council.

WAC 51-55-003 International Wildland-Urban Interface Code.

The 2021 edition of the *International Urban-Interface Code*, published by the International Code Council, is hereby adopted by reference with the following additions, deletions, and exceptions.

WAC 51-55-008 Implementation.

The International Wildland-Urban Interface Code adopted by this chapter shall become effective in all counties and cities of this state on July 1, 2023.

101.2 Scope. The provisions of this code shall apply to the construction, alteration, movement, repair, maintenance and use of any building, structure, or premises within the wildland-urban interface areas in this jurisdiction.

Buildings or conditions in existence at the time of the adoption of this code are allowed to have their use or occupancy continued, if such condition, use or occupancy was legal at the time of the adoption of this code, provided that such continued use does not constitute an egregious distinct danger to life or property. ||

Buildings or structures moved into or within the jurisdiction shall comply with the provisions of this code for new buildings or structures.

101.4 Retroactivity. The provisions of the code shall apply to conditions arising after the adoption thereof, conditions not legally in existence at the adoption of this code and conditions that, as determined by in the opinion of the code official, constitute an egregious distinct hazard to life or property. ||

EXCEPTION: Provisions of this code that specifically apply to existing conditions are retroactive.

INTENTIONALLY LEFT BLANK

ACCESSORY STRUCTURE. A building or structure used to shelter or support any material, equipment, chattel or occupancy other than a habitable building, or a habitable building or structure that is accessory to and incidental to that of the dwelling(s) and that is located on the same lot. ||

BUILDING OFFICIAL. Not adopted. ||

EGREGIOUS DANGER. A danger that if left unmitigated, places the occupants or property in immediate danger. ||

FUEL, HEAVY. Vegetation consisting of round wood 3 to 8 inches (76 to 203 mm) in diameter. See Fuel Models G, I, J, K, and U described in Chapter 9 Appendix D. ||

FUEL, LIGHT. Vegetation consisting of herbaceous plants and round wood less than 1/4-inch (6.4 mm) in diameter. See Fuel Models A, C, E, L, N, P, R, and S described in Chapter 9 Appendix D. ||

FUEL, MEDIUM. Vegetation consisting of round wood 1/4 to 3 inches (6.4 mm to 76 mm) in diameter. See Fuel Models B, D, F, H, O, Q, and T described in Chapter 9 Appendix D.

HIGH-DENSITY VEGETATED AREA. An area defined by a square determined in accordance with Section 302.3.1, with 75 percent or more vegetation.

||

||

WASHINGTON WILDLAND-URBAN INTERFACE MAP (WA-WUI). The Washington department of natural resources map designating urban areas, wildland-urban interface, wildland-urban intermix, wildlands, and long-term non-buildable areas, designated as the Washington wildland-urban interface as mapped for 2019 by the Washington state department of natural resources—wildfire and forest health divisions under consultation from the USFS Rocky Mountain Research Station.

WILDLAND-URBAN INTERFACE/INTERMIX AREA. That geographical area where structures and other human development meets or intermingles with wildland or vegetative fuels.

INTENTIONALLY LEFT BLANK

301.1 Scope. Wildland urban interface areas shall be determined using the Washington wildland urban of fact in accordance with Section 302.
User note: The WA-WUI map is available at <https://data-wadnr.opendata.arcgis.com/apps/wildland-urban-interface-viewing-app/explore>.

301.2 Construction in wildland-urban interface or intermix areas. Where a structure is proposed to be

301.3 Construction in wildlands areas. Where a structure is proposed to be constructed in an area

302.1 General. Wildland urban interface area designations are permitted to be established in accordance

302.2 Finding of fact. The applicable wildland urban interface designation shall be based on a finding of

302.3 Simplified wildland urban interface designation worksheet. The wildland urban interface

302.3.1 Area to be evaluated. For the purposes of establishing structure and vegetation densities, the

302.3.2 Structure density category. The structure density category shall be determined by counting the

UNINHABITED:	0 structures
VERY LOW:	1 structure
LOW:	2 to 8 structures
MEDIUM:	9 to 120 structures
HIGH:	more than 120 structures

302.3.3 Vegetation density category. Vegetation coverage within the area to be evaluated per Section

302.3.1 shall be determined in accordance with Chapter 9. Vegetation density shall be determined by

302.3.4 Proximity category. The distance from the site being evaluated to a high-density vegetated area density vegetated area. Where the distance is less than 1.5 miles, the proximity category shall be near. Where the distance is 1.5 miles or more, the proximity category shall be distant.

302.3.5 WUIC applicability. The WUIC shall apply, and the site shall be designated as intermix or

302.3.6 Wildland urban interface area designation. Where required by Section 302.3.5, the site shall

302.3.6.1 Intermix designation. The site shall be designated as intermix where the structure density

302.3.6.2 Interface designation. The site shall be designated as interface where the structure density

Figure 302(1).

UNINHABITED	VERY LOW	LOW	MEDIUM	HIGH
0	1	2 TO 8	9 TO 120	MORE THAN 120

2. Determine vegetation density category within the area determined by Section 302.3.1.

NONVEGETATED	VEGETATED
Less than 50% vegetated	50% or more vegetated

3. Determine proximity category to the nearest high-density vegetated area.

NEAR	DISTANT
Less than 1.5 mi (2.414 km)	1.5 mi (2.414 km) or more

4. Use structure density, vegetation density, and proximity categories from above to determine if WUIC applies.

WUIC Applies	WUIC Does Not Apply
• Structure density category is very low to high; and • Vegetation density category is vegetated.	• Structure density category is uninhabited; and • The site is not located within an area designated as intermix or interface on the WA-WUI map.
• Structure density category is very low to high; and • Proximity category is near.	• Structure density category is uninhabited to high; and • Vegetation density category is non-vegetated; and • Proximity category is distant.

5. Where WUIC applies, the site shall be designated as intermix or interface as follows:

INTERMIX	INTERFACE
• Structure density category is very low to high; and	• Structure density category is very low to high; and
• Vegetation density category is vegetated.	• Proximity category is near.

Figure 302(2).
simplified procedure for determining wildland interface designation

302.4 Review of wildland-urban interface areas. The *code official* shall review for approval evaluated areas for new or modified findings of fact. Where a new or modified findings of fact are approved, the *code official* shall recommend to WADNR a modification to the *wildland-urban interface areas* mapping.

401.1 Scope. *Wildland-urban interface areas* shall be provided with emergency vehicle access and water supply in accordance with this chapter.

401.2 Objective. This section is not adopted.

401.3 General safety precautions. This section is not adopted.

402.1 Subdivisions. Subdivisions shall comply with locally adopted standards.

402.1.1 Access. This section is not adopted.

402.1.2 Water supply. This section is not adopted.

402.2 Individual structures. Individual structures shall comply with Sections 402.2.1 and 402.2.2.

402.2.1 Access. Individual structures hereafter constructed or relocated into or within *wildland-urban interface areas* shall be provided with ~~fire apparatus access in accordance with the International Fire Code and~~ driveways in accordance with Section 403.2 and locally adopted standards. Marking of fire protection equipment shall be provided in accordance with Section 403.5 and address markers shall be provided in accordance with Section 403.6.

402.2.2 Water supply. Individual structures hereafter constructed or relocated into or within *wildland-urban interface areas* shall be provided with a conforming water supply in accordance with locally adopted standards ~~Section 404.~~

EXCEPTIONS: Not Adopted

402.3 Existing conditions. This section is not adopted.

403.2.1 Dimensions. This section is not adopted.

403.2.2 Length. This section is not adopted.

403.2.3 Service limitations. This section is not adopted.

403.2.4 Turnarounds and turnouts. Driveways in excess of three hundred feet in length shall be

required by locally adopted standards.

403.2.5 Turnouts. This section is not adopted.

403.3 Fire apparatus access road. Where required, fire apparatus access roads shall be provided and

all-weather road surface shall be any surface material acceptable to the code official that would normally allow the passage of emergency service vehicles typically used to respond to that location within the

403.4 Marking of roads. This section is not adopted.

403.4.1 Sign construction. This section is not adopted.

404.1 General. Water supply shall be provided and maintained as required by locally adopted standards.

404.2 Water sources. This section is not adopted.

404.3 Draft sites. This section is not adopted.

404.3.1 Access. This section is not adopted.

404.3.2 Pumper access points. This section is not adopted.

404.4 Hydrants. This section is not adopted.

404.5 Adequate water supply. This section is not adopted.

404.6 Fire department. This section is not adopted.

404.7 Obstructions. This section is not adopted.

404.8 Identification. This section is not adopted.

404.9 Testing and maintenance. This section is not adopted.

404.10 Reliability. This section is not adopted.

404.10.1 Objective. This section is not adopted.

404.10.2 Clearance of fuel. This section is not adopted.

404.10.3 Standby power. This section is not adopted.

501.1 General. Buildings and structures ~~shall be hereafter~~ constructed, modified, or relocated into or

2. Accessory structures not exceeding 200 square feet (11 m2) in floor area and where located not less than 50 feet (15,240 mm) from buildings or structures containing habitable spaces.

3. Agricultural buildings located not less than 50 feet (15,240 mm) from buildings or structures containing habitable spaces.

501.2 Objective. This section is not adopted.

501.4 Roof covering. Roofs shall have a roof assembly that complies with a Class A rating when tested

complying with ASTM D3909 installed over the combustible roof deck.

concrete roof tile or slate installed on noncombustible decks or ferrous, copper or metal sheets installed without a roof deck on noncombustible framing.

501.4.1 Roof valleys. Where provided, valley flashings shall be not less than 0.019-inch (0.48 mm) (No.

underlayment consisting of one layer of 72-pound (32.4 kg) mineral-surfaced, nonperforated cap sheet complying with ASTM D3909 running the full length of the valley.

501.5 Exterior walls and projections other than decks. Exterior walls and projections other than decks, of buildings, or structures, or *accessory structures* attached to buildings or structures with habitable

the foundation to the underside of the roof sheathing:

side.

Code; or

no greater than 1/4-inch maximum to prevent accumulation of combustibles and to prevent embers from coming in underneath.

501.6 Decks and appendages. The material of decks, porches, balconies, and stairs shall be

503.2.

2. Exterior fire-retardant-treated wood.

attached exterior wall covering is also either noncombustible or ignition-resistant material.

greater than 24 inches on center.

501.6.1 Clearance. Decks with less than 48 inches of clearance from finished grade to deck joists shall be enclosed with screen material with openings no greater than 1/4-inch maximum to prevent

501.6.2 Walking surfaces. The walking surface material of decks, porches, balconies, and stairs shall be constructed with one of the following materials:

2. Exterior fire-retardant-treated wood.

Section 501.6, natural wood decking products shall be:

accordance with ASTM E2632 and when attached exterior wall covering is also composed of only noncombustible or ignition-resistant materials.

decking surface material complies with the performance requirements of ASTM E84 with a Class B flame

501.6.2.1 Material in Section 501.6.2, Item 5. The walking surface material shall be tested in

be less than or equal to 25 kW/ft² (269 kW/m²). If any one of the three tests does not meet the conditions of acceptance, three additional tests shall be run. All the additional tests shall meet the condition of

501.7 Exterior glazing. Exterior windows, window walls and glazed doors, windows within exterior doors, and skylights shall be tempered glass, multilayered glazed panels, glass block, or have a fire protection rating of not less than 20 minutes.

501.8 Vents. Attic ventilation openings, foundation or underfloor vents, or other ventilation openings in vertical exterior walls and vents through roofs shall not exceed 144 square inches (0.0929 m²)

exceed 1/4 inch (6.4 mm) or shall be designed and approved to prevent flame or ember penetration into the structure.

1. Attic ventilation openings shall not be located in soffits, in eave overhangs, between rafters at eaves, or in other overhang areas. Gable end and dormer vents shall be located not less than 10 feet (3048 mm) from lot lines. Underfloor ventilation openings shall be located as close to grade as possible.

Insert Page 5-1 #2

Insert Facing Insert page 5-1 #3

502.1 General. The fire hazard severity of building sites for buildings hereafter constructed, modified, or relocated into *wildland-urban interface areas* shall be established in accordance with Table 502.1. See also, Chapter 8.~~Appendix C~~

||

502.2 Fire hazard severity reduction. The fire hazard severity identified in Table 502.1 is allowed to be reduced by implementing a vegetation management plan in accordance with Chapter 7.~~Appendix B~~

||

INTENTIONALLY LEFT BLANK

INTENTIONALLY LEFT BLANK

504.7 Appendages and projections. ~~Unenclosed~~ *Accessory structures* attached to buildings with than 1-hour fire-resistance-rated construction, *heavy timber construction*, or constructed of one of the following:

1. *Approved noncombustible materials.*
2. Fire-retardant-treated wood identified for exterior use and meeting the requirements of Section 2303.2 of the *International Building Code*.
3. Ignition-resistant building materials in accordance with Section 503.2.

EXCEPTION: Not Adopted

504.8 Decks and appendages. The material of decks, porches, balconies, and stairs shall be

503.2.

2. Exterior fire-retardant-treated wood.

attached exterior wall covering is also either noncombustible or ignition-resistant material.

greater than 24 inches on center.

504.8.1 Clearance. Decks with less than 48 inches of clearance from finished grade to deck joists shall be enclosed with screen material with openings no greater than 1/4-inch maximum to prevent

504.8.2 Walking surfaces. The walking surface material of decks, porches, balconies, and stairs shall be constructed with one of the following materials:

2. Exterior fire-retardant-treated wood.

Section 501.6, natural wood decking products shall be:

accordance with ASTM E2632 and when attached exterior wall covering is also composed of only noncombustible or ignition-resistant materials.

the decking surface material complies with the performance requirements of ASTM E84 with a Class B flame spread index.

504.8.2.1 Material in Section 504.8.1, Item 5. The walking surface material shall be tested in accordance with ASTM E2632 and shall comply with the following condition of acceptance. The ASTM E2632 test shall be conducted on a minimum of three test specimens and the peak heat release rate shall be less than or equal to 25 kW/ft² (269 kW/m²). If any one of the three tests does not meet the conditions of acceptance, three additional tests shall be run. All the additional tests shall meet the condition of acceptance.

504.98 Exterior glazing. Exterior windows, window walls and glazed doors, windows within exterior doors, and skylights shall be tempered glass, *multilayered glazed panels*, glass block or have a fire protection rating of not less than 20 minutes.

504.109 Exterior doors. Exterior doors shall be *approved* noncombustible construction, solid core wood not less than 1 3/4 inches thick (44 mm) or have a fire protection rating of not less than 20 minutes. Windows within doors and glazed doors shall be in accordance with Section 504.8.

EXCEPTION: Vehicle access doors.

504.1140 Vents. Attic ventilation openings, foundation or underfloor vents, or other ventilation openings in vertical exterior walls and vents through roofs shall not exceed 144 square inches (0.0929 m²) each. Such vents shall be covered with *noncombustible* corrosion-resistant mesh with openings not to exceed 1/4 inch (6.4 mm) or shall be designed and *approved* to prevent flame or ember penetration into the structure.

504.1140.1 Vent locations. Attic ventilation openings shall not be located in soffits, in eave overhangs, between rafters at eaves, or in other overhang areas. Gable end and dormer vents shall be located not less than 10 feet (3048 mm) from lot lines. Underfloor ventilation openings shall be located as close to grade as practical.

504.1244 Detached accessory structures. Detached accessory structures located less than 50 feet (15,240 mm) from a building containing habitable space shall have exterior walls constructed with materials *approved* for not less than 1-hour *fire-resistance-rated construction*, heavy timber, *log wall construction*, or constructed with *approved noncombustible* materials or fire-retardant-treated wood on the exterior side. The fire-retardant-treated wood shall be labeled for exterior use and meet the requirements of Section 2303.2 of the *International Building Code*.

504.1244.1 Underfloor areas. Where the detached structure is located and constructed so that the structure or any portion thereof projects over a descending slope surface greater than 10 percent, the area below the structure shall have underfloor areas enclosed to within 6 inches (152 mm) of the ground, with exterior wall construction in accordance with Section 504.5 or underfloor protection in accordance with Section 504.6.

EXCEPTION: The enclosure shall not be required where the underside of exposed floors and exposed structural columns, beams and supporting walls are protected as required for exterior 1-hour *fire-resistance-rated construction* or *heavy timber construction* or fire-retardant-treated wood on the exterior side. The fire-retardant-treated wood shall be labeled for exterior use and meet the requirements of Section 2303.2 of the *International Building Code*.

505.7 Appendages and projections. ~~Unenclosed~~ *Accessory structures* attached to buildings with habitable spaces and projections, ~~such as other than decks, porches, balconies, or stairs,~~ shall be not less than 1-hour *fire-resistance-rated construction*, *heavy timber construction* or constructed of one of the following:

1. *Approved noncombustible* materials.
2. Fire-retardant-treated wood identified for exterior use and meeting the requirements of Section 2303.2 of the *International Building Code*.
3. Ignition-resistant building materials in accordance with Section 503.2.

EXCEPTION: Not adopted.

505.8 Decks and appendages. The material of decks, porches, balconies, and stairs shall be

503.2.

2. Exterior fire-retardant-treated wood.

attached exterior wall covering is also either noncombustible or ignition-resistant material.

greater than 24 inches on center.

505.8.1 Clearance. Decks with less than 48 inches of clearance from finished grade to deck joists shall be enclosed with screen material with openings no greater than 1/4-inch maximum to prevent

505.8.2 Walking surfaces. The walking surface material of decks, porches, balconies, and stairs shall be constructed with one of the following materials:

2. Exterior fire-retardant-treated wood.

Section 501.6, natural wood decking products shall be:

accordance with ASTM E2632 and when attached exterior wall covering is also composed of only noncombustible or ignition-resistant materials.

decking surface material complies with the performance requirements of ASTM E84 with a Class B flame

505.8.2.1 Material in Section 505.8.1, Item 5. The walking surface material shall be tested in

be less than or equal to 25 kW/ft² (269 kW/m²). If any one of the three tests does not meet the conditions of acceptance, three additional tests shall be run. All the additional tests shall meet the condition of acceptance.

505.98 Exterior glazing. Exterior windows, window walls and glazed doors, windows within exterior doors, and skylights shall be tempered glass, *multilayered glazed panels*, glass block or have a fire protection rating of not less than 20 minutes.

505.109 Exterior doors. Exterior doors shall be *approved noncombustible* construction, solid core wood not less than 1 3/4 inches thick (45 mm) or have a fire protection rating of not less than 20 minutes. Windows within doors and glazed doors shall be in accordance with Section 505.8.

EXCEPTION: Vehicle access doors.

Insert Page 5-5 #1

Insert Facing Insert Page 5-5 #2

505.1140 Vents. Attic ventilation openings, foundation or underfloor vents or other ventilation openings in vertical exterior walls and vents through roofs shall not exceed 144 square inches (0.0929 m²) each. Such vents shall be covered with *noncombustible* corrosion-resistant mesh with openings not to exceed 1/4 inch (6.4 mm) or shall be designed and *approved* to prevent flame or ember penetration into the structure.

505.1140.1 Vent locations. Attic ventilation openings shall not be located in soffits, in eave overhangs, between rafters at eaves, or in other overhang areas. Gable end and dormer vents shall be located not less than 10 feet (3048 mm) from lot lines. Underfloor ventilation openings shall be located as close to grade as practical.

505.1244 Detached accessory structures. Detached accessory structures located less than 50 feet (15,240 mm) from a building containing habitable space shall have exterior walls constructed with materials *approved* for not less than 1-hour *fire-resistance-rated construction*, heavy timber, *log wall construction*, or constructed with *approved noncombustible* materials or fire-retardant-treated wood on the exterior side. The fire-retardant-treated wood shall be labeled for exterior use and meet the requirements of Section 2303.2 of the *International Building Code*.

505.1244.1 Underfloor areas. Where the detached *accessory structure* is located and constructed so that the structure or any portion thereof projects over a descending slope surface greater than 10 percent, the area below the structure shall have underfloor areas enclosed to within 6 inches (152 mm) of the ground, with exterior wall construction in accordance with Section 505.5 or underfloor protection in accordance with Section 505.6.

EXCEPTION: The enclosure shall not be required where the underside of exposed floors and exposed structural columns, beams and supporting walls are protected as required for exterior 1-hour *fire-resistance-rated construction* or heavy-timber construction or fire-retardant-treated wood on the exterior side. The fire-retardant-treated wood shall be labeled for exterior use and meet the requirements of Section 2303.2 of the *International Building Code*.

507.1 General. The *roof covering* on buildings or structures in existence prior to the adoption of this code that are replaced or have ~~25~~ 50 percent or more replaced in a 12-month period shall be replaced with a *roof covering* required ~~for new construction by Section 501.4 or~~ based on the type of ignition-resistant construction ~~specified in accordance with Section 503~~ as determined by Section 501.1 Exception 1.

INTENTIONALLY LEFT BLANK

INTENTIONALLY LEFT BLANK

602.1 General. An *approved* automatic sprinkler system shall be installed in all occupancies in new buildings required to meet the requirements for Class 1 ignition-resistant construction in Chapter 5 when required by the authority having jurisdiction. The installation of the automatic sprinkler systems shall be in accordance with nationally recognized standards.

Chapter 7
Vegetation management plan.
(See Appendix B on Page B-1)

User note: *About this chapter: #s The purpose of this chapter is to provide criteria for submitting vegetation management plans, specifying their content and establishing a criterion for considering vegetation management as being a fuel modification.*

INTENTIONALLY LEFT BLANK

Chapter 8
Fire hazard severity form.
(See Appendix C on Page C-1)

User note: About this ~~appendix chapter~~: ~~While not part of the code, it can become part of the code (replacing Table 502.1) when specifically included in the adopting ordinance. It's~~ The purpose of this chapter is to provide an alternative methodology to using Table 502.1 for analyzing the fire hazard severity of building sites using a preassigned value/scoring system for each feature that impacts the hazard level of a building site. Included in the evaluation are site access, types and management of vegetation, percentage of defensible space on the site, site topography, class of roofing and other construction materials used on the building (existing or to be constructed on the site), fire protection water supply, and whether utilities are installed above or below ground.

Insert Facing Insert Page CH-7-2

Intentionally Left Blank

Insert Page CH-8-2

Chapter 9
Fire danger rating system.
(See Appendix D on Page D-1)

User note: *About this appendix chapter: The fuel models included in Appendix-D Chapter 9 are only general descriptions because they represent all wildfire fuels from Florida to Alaska and from the East Coast to California.*

The National Fire Danger Rating System (NFDRS) is a set of computer programs and algorithms that allows land management agencies to estimate today's or tomorrow's fire danger for a given rating area. NFDRS characterizes fire danger by evaluating the approximate upper limit of fire behavior in a fire danger rating area during a 24-hour period based on fuels, topography and weather, or what is commonly called the fire triangle. Fire danger ratings are guides for initiating pre-suppression activities and selecting the appropriate level of initial response to a reported wildfire in lieu of detailed, site- and time-specific information.

Predicting the potential behavior and effects of wildland fire are essential tasks in fire management. Surface fire behavior and fire effects models and prediction systems are driven in part by fuel-bed inputs such as load, bulk density, fuel particle size, heat content and moisture content. To facilitate use in models and systems, fuel-bed inputs have been formulated into fuel models. A fuel model is a set of fuel-bed inputs needed by a particular fire behavior or fire effects model. Different kinds of fuel models are used in fire spread models in a variety of fire behavior modeling systems. The fuel models in this appendix correlate with the light, medium, and heavy fuel definitions found in Chapter 2 of the code.

INTENTIONALLY LEFT BLANK

INTENTIONALLY LEFT BLANK

ASTM

**E2632-2020: Standard Test Method for Evaluating the Under-Deck Fire Test Response of Deck
Materials**

501.6

INTENTIONALLY LEFT BLANK

CHAPTER 7 VEGETAION MANAGEMENT PLAN

User note: *About this chapter: It's The purpose of this chapter is to provide criteria for submitting vegetation management plans, specifying their content and establishing a criterion for considering vegetation management as being a fuel modification.*

B4701.1 Scope. Vegetation management plans shall be submitted to the *code official where required* for review and approval as part of the plans required for a permit.

B4701.2 Plan content. Vegetation management plans shall describe all actions that will be taken to prevent a fire from being carried toward or away from the building. A vegetation management plan shall include the following information:

1. A copy of the site plan.
2. Methods and timetables for controlling, changing, or modifying areas on the property. Elements of the plan shall include removal of slash, snags, vegetation that may grow into overhead electrical lines, other ground fuels, ladder fuels and dead trees, and the thinning of live trees.
3. A plan for maintaining the proposed fuel-reduction measures.

B4701.3 Fuel modification. To be considered a *fuel modification* for purposes of this code, continuous maintenance of the clearance is required.

INTENTIONALLY LEFT BLANK

**CHAPTER 8
FIRE HAZARD SEVERITY FORM**

User note: About this ~~appendix chapter~~: ~~While not part of the code, it can become part of the code (replacing Table 502.1) when specifically included in the adopting ordinance. It's~~ The purpose of this chapter is to provide an alternative methodology to using Table 502.1 for analyzing the fire hazard severity of building sites using a preassigned value/scoring system for each feature that impacts the hazard level of a building site. Included in the evaluation are site access, types and management of vegetation, percentage of defensible space on the site, site topography, class of roofing and other construction materials used on the building (existing or to be constructed on the site), fire protection water supply, and whether utilities are installed above or below ground.

C4801 Fire hazard severity form. Where adopted, Table 801.1 is permitted to be used as an alternative to Table 502.1 for analyzing the fire hazard severity of building sites.

**TABLE C4801.1
FIRE HAZARD SEVERITY FORM
(No change to the table)**

INTENTIONALLY LEFT BLANK

CHAPTER 9 FIRE DANGER RATING SYSTEM

User note: About this ~~appendix~~ chapter: The fuel models included in ~~Appendix-D~~ Chapter 9 are only general descriptions because they represent all wildfire fuels from Florida to Alaska and from the East Coast to California.

||

The National Fire Danger Rating System (NFDRS) is a set of computer programs and algorithms that allows land management agencies to estimate today's or tomorrow's fire danger for a given rating area. NFDRS characterizes fire danger by evaluating the approximate upper limit of fire behavior in a fire danger rating area during a 24-hour period based on fuels, topography, and weather, or what is commonly called the fire triangle. Fire danger ratings are guides for initiating pre-suppression activities and selecting the appropriate level of initial response to a reported wildfire in lieu of detailed, site- and time-specific information.

Predicting the potential behavior and effects of wildland fire are essential tasks in fire management. Surface fire behavior and fire effects models and prediction systems are driven in part by fuel-bed inputs such as load, bulk density, fuel particle size, heat content and moisture content. To facilitate use in models and systems, fuel-bed inputs have been formulated into fuel models. A fuel model is a set of fuel-bed inputs needed by a particular fire behavior or fire effects model. Different kinds of fuel models are used in fire spread models in a variety of fire behavior modeling systems. The fuel models in this appendix correlate with the light, medium, and heavy fuel definitions found in Chapter 2 of the code.

D4901.1 General. The Fuel Model Key is provided in Table 901.1. Fuel Models are described in Sections 901.1.1 through 901.1.20.

**TABLE D4901.1
FUEL MODEL KEY
(No change to the table)**

INTENTIONALLY LEFT BLANK

D4901.1.1 FUEL MODEL A. (No change to the text)

D4901.1.2 FUEL MODEL B. (No change to the text)

D4901.1.3 FUEL MODEL C. (No change to the text)

D4901.1.4 FUEL MODEL D. (No change to the text)

D4901.1.5 FUEL MODEL E. (No change to the text)

D4901.1.6 FUEL MODEL F. (No change to the text)

D4901.1.7 FUEL MODEL G. (No change to the text)

D4901.1.8 FUEL MODEL H. (No change to the text)

D4901.1.9 FUEL MODEL I. (No change to the text)

D4901.1.10 FUEL MODEL J. (No change to the text)

D4901.1.11 FUEL MODEL K. (No change to the text)

D4901.1.12 FUEL MODEL L. (No change to the text)

D4901.1.13 FUEL MODEL N. (No change to the text)

D4901.1.14 FUEL MODEL O. (No change to the text)

D4901.1.15 FUEL MODEL P. (No change to the text)

D4901.1.16 FUEL MODEL Q. (No change to the text)

D4901.1.17 FUEL MODEL R. (No change to the text)

D4901.1.18 FUEL MODEL S. (No change to the text)

D4901.1.19 FUEL MODEL T. (No change to the text)

D4901.1.20 FUEL MODEL U. (No change to the text)

INTENTIONALLY LEFT BLANK